







Numero / Number | 6700                      Sostituisce / Replaces --  
Emesso / Issued    06/04/2009                      Scopo / Scope                      Directive 92/42/CEE

Annex 1 to certificate PIN 0694BR0988

Pag. 1 di 1

Attribuzione delle marcature di rendimento energetico:  
*Award of Energy-Performance labels:*

Marchio / trade mark:                      **IMMERGAS**

Modelli / models:

Livello stelle / Star level:

VICTRIX ZEUS 26 KW  
VICTRIX ZEUS 26 1 I



\* Rendimento al carico parziale per caldaie modulanti secondo la EN483/A2.  
*Efficiency partload for modulating boilers according to EN483/A2*

**Kiwa Italia S.p.a.**

Ronald Karel  
Procuratore Generale

**Kiwa Italia S.p.a.**

*Sede Legale:*  
Via G. Carducci, 5  
20123 Milano

*Sede Amministrativa e operativa:*  
Via Treviso, 32/34  
31020 San Vendemiano (TV)

**GASTEC**

**Notified Body**

**0694**



Kiwa Italia S.p.a.

Sede Legale:

Via G. Carducci, 5 - 20123 Milano (MI)

Sede Amministrativa:

Via Treviso, 32/34 - 31020 San Vendemiano (TV)

Tel. +39 0438 411755 - Fax +39 0438 22428

Internet: www.kiwa.it - E-mail: info@kiwa.it

**DECLARATION ON BEHALF OF IMMERGAS S.p.A.**

Test performed on LPG/NG see note below	Original Boiler Name	UK Market Name	Full Load Efficiency (% net)	Part Load Efficiency (% net)
NG	VICTRIX ZEUS 26 KW	VICTRIX ZEUS 26 KW	96,9	107,9
NG	VICTRIX ZEUS 26 KW*	VICTRIX ZEUS 26 KW*	96,9	107,9
NG	VICTRIX ZEUS 26 1 I	VICTRIX ZEUS 26 1 I	96,9	107,9
NG	VICTRIX ZEUS 26 1 I*	VICTRIX ZEUS 26 1 I*	96,9	107,9

Boilers marked with an asterisk(\*) are LPG models where the tests were carried out using Natural Gas (G20).

We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive (see below) have been satisfied in obtaining these results.

Type of Boiler	Range of Power	Efficiency at rated output	Efficiency at part load
	KW	Average boiler-water temperature	Average boiler-water temperature
Standard boilers	4 to 400	70° C	≥ 50° C
Low temperature boilers <sup>1</sup>	4 to 400	70° C	40° C
Gas condensing boilers	4 to 400	70° C	30° C <sup>2</sup>

<sup>1</sup> Including condensing boilers using liquid fuels.

<sup>2</sup> Temperature of boiler water supply.

San Vendemiano, 06 April 2009

Signed on behalf of **Kiwa Italia Spa.**

**Kiwa Italia Spa.**



Ronald Karel  
Procuratore Generale